



NOTE: 1. IF BASE IS UNSTABLE, TRENCH SHALL BE UNDERCUT AND STABILIZED WITH TRENCH STABILIZATION MATERIAL. SPECIFICATIONS AS PER MANUFACTURER'S RECOMMENDATIONS AND A.S.T.M. C12.

2. BEDDING MATERIAL

95% PASSING 3/4" SEIVE
95% RETAINED #4 SEIVE

(CLEAN ANGULAR, WELL-GRADED, CRUSHED ROCK. PEA ROCK MAY BE USED FOR SANITARY SEWER SERVICE LINES.)

3. THE REQUIRED BEDDING MATERIAL UNDER THE BOTTOM OF THE PIPE SHALL BE INSTALLED PRIOR TO PIPE INSTALLATION.

Revised: November 2015

City of Madison
Engineering Department
Sanitary Sewer Main
Bedding Detail



PO Box 308
116 W. Center Street
Madison, SD 57042
Phone: (605)256-7514
Fax: (605)256-7511